



config INPUT du TT230 ETH

- IN2 → POSITIVE LIMIT SWITCH
- IN3 → NEGATIVE LIMIT SWITCH
- INI → HOME SWITCH
- IN4 → QUICK STOP

\*\* Exemple de cablage non contractuel

- \* 13-14 cat d'arret 0 selon EN60204-1
- \* 23-24 cat d'arret 0 selon EN 60204-1
- \* 37-38 cat d'arret 1 selon EN 60204-4 (temporiz de 1 a 30 sec.)

Title MC405 analog 2x TT230		
Author GF Transtechnik		
File ematic\MC405\MC4N_2xTT230_ETHERCAT.dsn	Document	
Revision 1.2	Date 2013-03-03	Sheets 1 of 1

